

Notice of Public Hearing for  
**Town of Ridgway Ductile Iron Water Line Replacement Project**  
*Ridgway, Colorado*

Date: ***February 14, 2024***  
Time: ***5:30 p.m.***  
Location: ***Ridgway Town Hall***  
Address: ***201 N. Railroad St.  
Ridgway, CO 81432***  
Topic: **Town of Ridgway Ductile Iron Water Line Replacement Project**

Pursuant to the Town's Electronic Participation Policy, the meeting will be conducted both in person and via a virtual meeting portal. Members of the public may attend in person at Ridgway Town Hall, located at 201 N. Railroad Street, Ridgway, Colorado 81432, or virtually using the meeting information below.

Join Zoom Meeting  
<https://us02web.zoom.us/j/82774268562?pwd=OGNyRmZ2YkNmaHl3ZGZleC9UODJSZz09>

Meeting ID: 827 7426 8562

Passcode: 956116

Dial by your location

+1 346 248 7799 US

+1 253 215 8782 US

A public hearing will be conducted for informing citizens and soliciting public input, written or oral, regarding the Town of Ridgway Ductile Iron Water Line Replacement Project Needs Assessment (PNA) and Environmental Assessment (EA) (if applicable). The PNA is a report detailing the project as proposed, including project necessity, alternatives, and components. The PNA also describes how the project is being funded. The reports are being submitted to the Colorado Department of Public Health and Environment (CDPHE) to qualify the Town of Ridgway for a State Revolving Fund Loan.

The transmission line from the Ridgway Water Treatment Plant to Amelia St. and Moffat St. includes about 4,000 feet of unshathed ductile iron pipe that is approaching the end of its useful life as evidenced by the significant break in the line in the spring of 2023 due to corrosion. At that time, Town staff noted potential corrosion on other sections of the pipe. The proposed project will replace all the ductile iron pipe in the transmission line with non-corrosive plastic pipe and install a master water meter on the new line. Constructing the project will require the installation of a temporary bypass line and reconnection of all the lines and services that are connected to the existing ductile line to the new pipe.

The estimated cost of the project according to the Preliminary Needs Assessment is \$1,250,000.

Copies of the PNA and EA (if applicable) are available for public review prior to the Public Hearing at the following location:

*Town of Ridgway  
201 N. Railroad St.  
Ridgway, Colorado*

The point of contact for the Town of Ridgway is Preston Neill, Town Manager. He can be contacted at 970-626-5308 ext. 212 or [pneill@town.ridgway.co.us](mailto:pneill@town.ridgway.co.us).

Town of Ridgway  
Preston Neill  
Town Manager